



**DEPARTMENT OF PUBLIC HEALTH AND SOCIAL SERVICES  
DIVISION OF ENVIRONMENTAL HEALTH  
CHILD CARE FACILITY  
INSPECTION REPORT**

<b>REASON</b>		<b>GRADE</b>  10	<b>Inspection Date:</b> 3/14/18		<b>ESTABLISHMENT NAME:</b> MILESTONES PLAY & LEARN CENTER	
Regular	<input checked="" type="checkbox"/>		<b>Time In/Out:</b> 5:14 PM   4:35 PM		<b>OWNER/OPERATOR:</b> ROSARIO, RON PIER Z	
Follow-Up	<input type="checkbox"/>					
Complaint	<input type="checkbox"/>		<b>Sanitary Permit No.:</b> 20000-17000305		<b>LOCATION:</b> 101-103 JRG <b>Establishment Type:</b> COMMERCIAL CTR. MAGATNA CCC / NURSERY	
Investigation	<input type="checkbox"/>					
Other:	<input type="checkbox"/>	<b>RATING</b>  A	<b>PERMIT STATUS:</b> <input checked="" type="checkbox"/> Valid <input type="checkbox"/> Temporary <input type="checkbox"/> Expired			
<b>No. of Children:</b> 29 Male 20 Female 49 Total			<b>Child Care License No.:</b> 120110 / <input checked="" type="checkbox"/> Valid / / Provisional / / Expired			

The following items identify violations found this day in the operations and facilities which must be corrected by the next inspection or sooner as the Department indicates. Non-compliance may result in downgrading or permit suspension. To appeal a written request for hearing must be submitted before the indicated correction date.

ITEM*	REMARKS	DEMERIT	CORRECT BY
	A REGULAR INSPECTION WAS CONDUCTED. PREVIOUS INSPECTION CONDUCTED ON 12/6/17 (7, A).		
	THE FOLLOWING VIOLATIONS WERE OBSERVED:		
17	PAINT PEELING ON LOWER WALL IN CLASSROOM #2. ALL WALLS & CEILINGS SHALL BE KEPT IN GOOD REPAIR TO PREVENT PHYSICAL HAZARDS.	2	4/14/18
21	NO HOT WATER PROVIDED FOR HANDSINKS THROUGHOUT THE ESTABLISHMENT. HOT WATER SHALL BE PROVIDED TO PROMOTE PROPER HANDWASH HYGIENE. * REPEAT VIOLATION. NOTE: NON-COMPLIANCE MAY RESULT IN DOWNGRADING OR PERMIT SUSPENSION	6	3/24/18
18	SELF-CLOSING DEVICE BROKEN ON KITCHEN EXIT DOOR. ALL OPENINGS SHALL BE MAINTAINED IN GOOD REPAIR TO PREVENT PEST ACCESS.	2	4/14/18
	"A" PLACARD #02354 ISSUED. PHOTOS TAKEN.		
	TIC BRIEFED ON ABOVE.		

I have read and understand the above violation(s) and I am aware of the corrective measures to be taken.

\*Note: When any of the following items are cited above, they shall be corrected within 10 days of this inspection:  
(2), (4), (6), (14), (21), (23), (24), (27), (28), (39) & (40).

Received By (Name & Title):

RON ROSARIO

3/14/18

DEH Inspector (Name & Title):

J. GARCIA EPIC C. TAKASE FT710